



**BRUNSWICK COUNTY ADMINISTRATION  
PUBLIC INFORMATION OFFICE  
BRUNSWICK COUNTY GOVERNMENT CENTER  
75 COURTHOUSE DRIVE, NE  
BOLIVIA, NORTH CAROLINA 28422**

Mailing Address:

Post Office Box 249  
Bolivia, NC 28422

e-mail: [bclegal@brunswickco.net](mailto:bclegal@brunswickco.net)

Time: 12 N, 10 VII 08

Telephone

(910) 253-2000  
(800) 442-7033 (NC)

Telecopy

(910) 253-2008

Rel. # 1

---

**NOTICE OF DISCHARGE OF UNTREATED WASTEWATER**

Brunswick County Public Utilities had a discharge of untreated wastewater from a sewer force main located at Brunswick Community College at the Student Center construction site. The approximate amount was 3,500 gallons. The spill was first reported on July 7, 2008, at 8:45 a.m., isolated and contained by 9:15 a.m., and repairs completed by 11:15 a.m.

The discharge was caused as a result of excavation work at the construction site that damaged the sewer force main. The lines were properly located on June 3, 2008. The contained spill was removed and area lime stabilized.

This notice is required by NC General Statutes Article 21 Chapter 143.215.C.

END